

Does Nuclear Energy Have a Role in the Development of Canada's Oil Sands?

Canadian International Petroleum Conference 2003 Calgary, Alberta, Canada

June 10-12, 2003

R.B. Dunbar, T.W. Sloan Canadian Energy Research Institute

CIPC Paper 2003-096



Overview

- The Canadian oil sands industry consumes large quantities of natural gas to supply its energy needs and produce hydrogen
 - The EUB expects Alberta crude bitumen production to reach 371 10³m³/d by 2012, a 2.8-fold increase from 2002
 - Based on the configuration of currently operating projects, it is estimated that achieving this production level would require 60-75 10⁶m³/d of natural gas in 2012 an unsustainable level
- The industry is working hard to reduce energy requirements and/or find alternative energy sources



CIPC Paper 2003-096

Canadian International Petroleum Conference 2003



CERI's Study

In response to this issue, Atomic Energy of Canada Limited (AECL) contracted the Canadian Energy Research Institute (CERI) to compare the economics of nuclear and gasfired options to supply steam to an oil sands reservoir using SAGD



CIPC Paper 2003-096



Study Objectives and Scope

Objectives

- Compare the economics of a modified Advanced Candu Reactor (ACR-700) with a gas-fired facility, to supply steam to a hypothetical SAGD project located in north-eastern Alberta
- Perform the comparison at a pre-feasibility level

Scope

- The study focussed on comparative economics it did not examine other issues that might be associated with nuclear development
- Follow-up studies may be carried out



CIPC Paper 2003-096



Supply Cost

- The economic comparison was made using supply cost methodology
- Supply cost is the constant dollar price that would recover all costs including:
 - Capital
 - Operating costs
 - Return on investment
- Supply cost is calculated using discounted cash flow techniques
- Supply costs for both the nuclear and the gasfired options were calculated before tax



CIPC Paper 2003-096




The ACR-700


- Evolutionary development of familiar CANDU technology with innovations for improvement of economics, operations and safety
- Gross output of 1983 MW_t and 728 MW_e in its normal configuration
- Slightly enriched uranium fuel
- Light water coolant
- Compact core design




CIPC Paper 2003-096

Canadian International Petroleum Conference 2003









CER

ACR 700 Nuclear Facility

CIPC Paper 2003-096

- 78,020 m³/d steam capacity (stream-day)
 - 80% quality steam; 3.0 MPa

3

- 390 Mb/d of 100% quality steam after separation
- 157 Mb/d of SAGD bitumen at a 2.5 SOR
- 100 MW net electrical output (stream-day)
- Costs (\$2002, stream-day)

Capital: \$1,400 million

Annual O&M (including fuel): \$83 millionSpent fuel management: \$8 million

•

On-stream date: April 1, 2011



CIPC Paper 2003-096



Gas-Fired Facility

- 78,020 m³/d steam capacity and 103 MW net electrical output (stream-day)
 - Alstom 11N2 Gas Turbine with electrical generator and HRSG (116.5 MW_e ISO rating)
 - 21 OTSGs (36.33 kg/s steam capacity per unit)
- Costs (\$2002, stream-day)

Capital: \$230 million
Annual O&M: \$8.5 million
Annual fuel: \$256 million
On-stream date: April 1, 2011



CIPC Paper 2003-096

11




Energy Price Assumptions


- Natural Gas
 - NYMEX: US\$3.50/MMBtu
 - Plant Gate: C\$4.25/GJ
- Electricity
 - Plant Gate: C\$50/MWh




CIPC Paper 2003-096

12









Other Considerations

- Staged Production and Risk Profile
- Hydrogen Production
- Steam Distribution
- Design Optimization
- Water Access



CIPC Paper 2003-096

6



Conclusions (1)

- Steam supply from an ACR-700 nuclear facility would be economically competitive with steam supply from a gas-fired facility
- Based on the configuration studied, the ACR-700 nuclear facility would support a very large SAGD project (23,200 m³/d) adequate bitumen reserves to support this scale of operations would need to be located within reasonable proximity of the central steam generation site



CIPC Paper 2003-096

17



Conclusions (2)

- Steam supply cost from a nuclear facility is very sensitive to capital cost
- Steam supply cost from a gas-fired facility is very sensitive to natural gas price and possible Kyoto compliance cost



CIPC Paper 2003-096

18